

ELECTRICAL INSPECTION

Inspections and Testing. In accordance with the International Building Code, Section 104.4, In sections, the building official is responsible for regulating construction, enforcing code requirements and shall make all of the required inspections. The building official has the authority of allowing approved agencies or approved individuals to conduct inspections. The approved agencies or individual shall submit to the building official reports of inspections in writing and certified by a responsible officer of the approved agency or by the approved individual

Inspection Required. During and upon completion of any installation, alteration, or extension of an electrical wiring system, the Electrical Official shall inspect the work to assure compliance with the electrical code.

Concealed Work. During and upon completion of any installation, alteration, or extension of an electrical wiring system, the Electrical Official shall inspect the work to assure compliance with the electrical code.

Conformity. The Electrical Official shall within a reasonable time after notice of the completion of the electrical wiring for which a permit is required by this code, make or cause to be made an inspection of such work and such tests as may be necessary to determine that it conforms to the code.

Re-inspection. The Electrical Official may conduct any re-inspection in the interest of public safety. If an electrical wiring system is found to be defective and unsafe, the electrical official shall revoke all certificates relating to such systems, and the use of such system shall be discontinued until compliance is achieved and a new certificate issued.

Defective Work. If an electrical wiring system upon re-inspection is found to be defective and unsafe, the Electrical Official or his/her duly authorized designee shall revoke all certificates in effect at that time relating to such systems; and the use of such electrical wiring system shall be discontinued until it has been made to conform to this code and a new certificate of approval has been issued by the Electrical Official or his/her duly authorized designee.

Certificate of Approval. Upon the making of the final inspection of an electrical wiring system, if the same be approved, then the Electrical Official or his/her duly authorized designee shall issue or cause to be issued a certificate of approval, as hereinafter provided, and the same shall be attached to the electrical wiring system.

Approval Required. Work shall not be done beyond the point indicated in each successive inspection without first obtaining the approval of the Electrical Official. The Electrical Official upon notification shall make the requested inspections and shall either indicate the portion of the construction that is satisfactory as completed, or shall notify the permit holder or an agent of the permit holder wherein the same fails to comply with this code. Any portions that do not comply shall be corrected and such portion shall not be covered or concealed until approved.

Underground Inspection. Underground inspection is to be made after trenches or ditches are excavated, conduit or cable installed, and before any backfill is put in place.

Rough-in Inspection. Rough-in inspection is to be made after the roof, framing fire-blocking, bracing and rough wiring is in place and prior to the installation of wall or ceiling membranes.

Final Inspection. Final inspection is to be made after the building is complete, all required fixtures are in place and properly connected or protected, and the structure is ready for occupancy.

Violation Penalties. Any person who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter or repair electrical work in violation of the approved construction documents or directive of the electrical official, or of a permit or certificate issued under the provisions of this code, shall be subject to penalties in accordance with Chapter 1 of the Mobile City Code. Each day a violation continues after due notice has been served shall be deemed a separate offense.

Interference with electrical official. It shall be unlawful for any person to interfere with the electrical official or any of his/her duly authorized representatives when they are performing any of their duties as set out in this Code or in other ordinances of the city.

Violation of the provisions of the adopted National Electrical Code (NEC) being enforced by the City of Mobile shall be subject to \$250.00 unless listed below:

- | | |
|---|----------|
| (a) Working without a Certificate of Competency | \$500.00 |
| (b) Interference with Electrical Official. | \$100.00 |
| (c) Signage on all vehicles used by contractor. | \$100.00 |

Regulation of Master Electricians. See the adopted City of Mobile’s Ordinance Adopting the National Electrical Code.

Regulation of Maintenance Electricians. See the adopted City of Mobile’s Ordinance Adopting the National Electrical Code.

Regulation of Journeyman Electricians. See the adopted City of Mobile’s Ordinance Adopting the National Electrical Code.

Regulation of Low Voltage Contractors. See the adopted City of Mobile’s Ordinance Adopting the National Electrical Code.

ELECTRICAL INSPECTIONS

Electrical Final Inspection.	Rough-In Slab Inspection.
Electrical Final Re-Inspection.	Rough-In Slab Re-Inspection.
Investigation Complaint	Rough-In Walls Inspection.
Investigation Complaint Re-Investigation.	Rough-In Walls Re-Inspection.
Investigation 6 Months Inspection.	Service Inspection.
Investigation 6 months Re-Inspection.	Service Re-Inspection.
Investigation Alarms Inspection.	Service Relocate Inspection.
Investigation Alarms Re-Inspection.	Service Relocate Re-Inspection.
Partial Ok Inspection.	Signs Inspection.

Partial OK Re-Inspection.

Pool Bond Inspection.

Pool Bond Re-Inspection.

Pool Final Inspection.

Pool Final Re-Inspection.

Repair Inspection.

Repair Re-Inspection.

Rough-In Ceiling Inspection.

Rough-In Ceiling Re-Inspection

Signs Re-Inspection.

Special Systems Inspection.

Special Systems Re-Inspection.

Temporary Power Pole Inspection.

Temporary Power Pole Re-Inspection.

Trench Inspection.

Trench Re-Inspection.

Upgrade Inspection.

Upgrade Re-Inspection.