

NAPOLEON SUBDIVISION

Engineering Comments: Must comply with all storm water and flood control ordinances. Any work performed in the right of way will require a right of way permit. Revised plat to include a minimum 25 foot radius to be dedicated to the City of Mobile at the intersection of St. Stephens Rd and Lafayette St. for both Lots. Drainage from dumpster pads cannot discharge to storm sewer; must have connection to sanitary sewer.

Traffic Engineering Comments: Driveway number, size, location, and design to be approved by Traffic Engineering and conform to AASHTO standards. Minimum parking aisle width is twenty-four feet. Changes should be made to accommodate this standard. There are also numerous conflict points in the parking lots that need to be remedied. Sufficient information is not provided for the driveway cuts and they appear substandard. Changes should be made to accommodate city standards.

Urban Forestry Comments: Property to be developed in compliance with state and local laws that pertain to tree preservation and protection on both city and private properties (State Act 61-929 and City Code Chapters 57 and 64).

Fire-Rescue Department Comments: No comments.

MAWSS Comments: No comments.

The plat illustrates the proposed 2-lot, 0.6± acre subdivision which is located at the Southeast and Northeast corners of North Lafayette Street and St. Stephens Road in Council District 2. The subdivision is served by public water and sanitary facilities.

The purpose of this application is to subdivide four metes-and-bounds parcels into two lots of record.

This is basically the same application as heard by the Commission in November, 2008, in conjunction with a Planned Unit Development application and a Rezoning application. Although recommended for approval by staff, the subdivision was denied due to the denial of the Planned Unit Development and Rezoning applications making the subdivision unnecessary. City Council subsequently took no action on the Rezoning application in March, 2009; therefore the request was nullified. The applicant has also submitted Use, Off-Site Parking, Buffer Fencing, and Buffer Fence Height Variance requests scheduled for the May 4, 2009 Board of Zoning Adjustment meeting.


As this application is not to be heard in conjunction with a new Rezoning application, there is no possibility of eliminating the current split zoning (R-1 and B-2) within the site area. Since there is a six-month waiting period before a new Rezoning application can be submitted, it would be October, 2009, at the earliest before one could be considered by the Commission. Policy is to not recommend approval for any subdivision containing split zoning unless an accompanying Rezoning is heard to eliminate such. As that is not the case in this instance, denial of this

application is the only possible recommendation, or holdover until the Board of Zoning Adjustment has heard and considered the variance requests.

Based on the preceding, the plat is recommended for denial for the following reasons:

- 1) as proposed, the plat would create a split-zoned subdivision; and
- 2) no Rezoning application accompanied this application, and none can be considered by the Commission until October, 2009, at the earliest.

LOCATOR MAP



APPLICATION NUMBER 13 DATE May 7, 2009

APPLICANT Napoleon Subdivision

REQUEST Subdivision



NAPOLEON SUBDIVISION



APPLICATION NUMBER 13 DATE May 7, 2009

LEGEND

R-1	R-2	R-3	R-A	R-B	H-B	T-B	B-1	LB-2	B-2	B-3	B-4	B-5	I-1	I-2



NAPOLEON SUBDIVISION



APPLICATION NUMBER 13 DATE May 7, 2009



NTS